



**Environmental
Protection Agency**

_____, Governor
_____, Lt. Governor
_____, Director

July 14, 2010

RE: WAYNE COUNTY
CHIPPEWA CREEK BASIN
CITY OF RITTMAN
NEW RITTMAN HIGH SCHOOL/
MIDDLE SCHOOL

Mr. Jon Ritchie
75 N. Main Street
Rittman, OH 44270

Dear Mr. Ritchie:

On July 13, 2010, Ohio EPA conducted an inspection of the New Rittman High School/ Middle School project, located at 100 Saurer Street, City of Rittman, Milton Township, Wayne County (site). Ohio EPA records indicate that the site is covered by the General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04408*AG. I was accompanied by Dave Juchnowski of C.T. Taylor Construction. The inspection documented the following:

- Inlet protection has been installed on the site's storm sewer inlets. Maintain inlet protection in accordance with the site's storm water pollution prevention plan (SWP3).
- The extended detention wetland pond has been installed and observed to be in working condition. All storm sewer inlets on-site discharge into the pond.
- Much of the site has been stabilized. Continue to stabilize the site in accordance with the site's SWP3.

Any above deficiencies must be addressed within 14 days of receiving this letter. Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,

Sean Green
Assistant to the District Engineer
Division of Surface Water

SG/mt

cc: Dave Juchnowski, C.T. Taylor Construction