



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 27, 2011

RE: WAYNE COUNTY  
CITY OF WOOSTER  
OAK HILL PARK  
CONSTRUCTION STORM WATER

Mr. Joel Montgomery  
City of Wooster  
538 N Market Street  
Wooster, OH 44691

Dear Mr. Montgomery:

On June 9, 2011, I, along with Roger Kobilarcsik and Dave Case of the City of Wooster, performed an inspection at the above-referenced site to determine compliance with the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC05407\*AG. Our records indicate that the City of Wooster was granted coverage under the NPDES permit on April 22, 2011.

During my inspection, I documented the following deficiencies:

1. The site lacks a designated concrete washout area. According to the NPDES permit, water used to wash out concrete trucks is considered waste water and must be kept onsite in a designated containment area. Please install a concrete washout before conducting further work with concrete.
2. The culverts that will allow the stream to pass under the trail are not in place. Please install these culverts immediately to prevent the stream from flowing over disturbed soil.
3. Please cover the sediment trap outlets with geotextile fabric and place gravel over these structures to ensure that the water entering the sediment traps is treated before being discharged.


Please provide me with a letter of response indicating the actions you will take to address the deficiencies noted above. Your response, along with any amendments to the SWP3, must be submitted to the Ohio EPA **no later than July 7, 2011**. If corrective actions are not completed by this date, please include a schedule that outlines when action will be taken. It is Ohio EPA's expectation that all of these deficiencies will be addressed within 10 days of receipt of this letter.

Mr. Joel Montgomery  
Oak Hill Park  
June 27, 2011  
Page 2

Finally, please fax a copy of your most recent storm water inspection report to my attention at (330) 487-0769 or via e-mail at [michelle.hummel@epa.state.oh.us](mailto:michelle.hummel@epa.state.oh.us). The NPDES permit requires you to inspect all storm water best management practices once every 7 days and within 24 hours of a 0.5-inch or greater rainfall. The results of these inspections must be documented as indicated in Part III.G.2.i of the NPDES permit.

If you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,



Michelle Hummel  
Assistant to the District Engineer  
Division of Surface Water

MH/mt

cc: Robert Breneman, Mayor, City of Wooster  
Wayne County SWCD

ec: Dan Bogoevski, Ohio EPA, NEDO, DSW

**Oak Hill Park**  
City of Wooster Wayne County

**Photos Taken:** June 9, 2011  
**By:** Michelle Hummel, DSW, NEDO




Figure 1 – A culvert is needed to prevent clean water from flowing over bare soil.




Figure 2 – The outlet to the sediment trap is not currently treating the runoff.