



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 27, 2011

RE: WAYNE COUNTY
WOOSTER TOWNSHIP
BATDORF AREA WASTEWATER SYSTEM
CONSTRUCTION STORM WATER

Mr. Terry West
Wayne County
428 W Liberty Street
Wooster, OH 44691

Dear Mr. West:

On June 9, 2011, I performed an inspection at the above-referenced site to determine compliance with the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC04940*AG. Our records indicate that Wayne County was granted coverage under the NPDES permit on May 25, 2010.

During my inspection, I documented the following deficiencies:

1. A great deal of sediment is present on the roadways. If the project is nearing completion, please patch any unpaved areas and permanently stabilize all bare areas. If there is still work to be done, please clean the streets regularly to prevent loose sediment from washing into the storm drains.
2. Some of the silt fence and inlet protection needs maintenance, especially along Mallard Way. Please repair these control practices and ensure that they are installed in accordance with the NPDES permit and the *Rainwater and Land Development Manual* (Ohio Department of Natural Resources, 2006).

Please provide me with a letter of response indicating the actions you will take to address the deficiencies noted above. Your response, along with a copy of the Storm Water Pollution Prevention Plan (SWP3) for the site, must be submitted to the Ohio EPA **no later than July 7, 2011**. If corrective actions are not completed by this date, please include a schedule that outlines when action will be taken. It is Ohio EPA's expectation that all of these deficiencies will be addressed within 10 days of receipt of this letter.

Finally, please fax a copy of your most recent storm water inspection report to my attention at (330) 487-0769 or via e-mail at michelle.hummel@epa.state.oh.us. The

Mr. Terry West
Batdorf Area Wastewater System
June 27, 2011
Page 2

NPDES permit requires you to inspect all storm water best management practices once every 7 days and within 24 hours of a 0.5-inch or greater rainfall. The results of these inspections must be documented as indicated in Part III.G.2.i of the NPDES permit.

If you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,



Michelle Hummel
Assistant to the District Engineer
Division of Surface Water

MH/mt

cc: Roger Terrill, Engineer, Wayne County
Trustees, Wooster Township
Wayne County SWCD

ec: Dan Bogoevski, Ohio EPA, NEDO, DSW