



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korfeski, Director

Re: Erie County  
Inter Strub Road & Columbus Avenue  
Construction  
Storm Water

August 13, 2010

Mr. Matthew J. Rogers  
Erie County Engineers Office  
2700 Columbus Avenue  
Sandusky, Ohio 44870

Dear Mr. Rogers:

On July 20, 2010, Sarah Clement inspected the Intersection of Strub Road (CR 7) and Columbus Avenue (CR 120) in Sandusky. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No 2 GC02326\*AG. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111. As a result of the inspection, your site may be eligible to terminate your NPDES permit.

It appeared that construction activities at the Intersection of Stub Road and Columbus Avenue are complete. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means:

All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment controls have been removed, properly disposed of, and all trapped sediment has been permanently stabilized.


- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

It appears that your site meets one or more of the above criteria. If you believe the same is true, please file the NOT form. The form can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be filed with Ohio EPA's Central Office within 45 days of when the above criteria are met.

Mr. Matthew J. Rogers  
August 13, 2010  
Page 2

If there are any questions, please contact me at (419) 373-3009.

Sincerely,



Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/llr

pc: ~~DSW-NWDO-File~~  
Michael Bixler, County Administrator  
Erie County SWCD