




**Environmental  
Protection Agency**

**John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director**



**NOTICE OF VIOLATION – ACTION REQUIRED**

August 27, 2012

Allen Dawson  
Hillcrest Manor Nursing Home  
6674 Stafford Street  
Washington Court House, OH 43160

**Fayette County  
Hillcrest Manor Nursing  
COMMUNITY PWS  
PWS ID: OH2400312**

Dear Mr. Dawson:

This letter is notification that the Hillcrest Manor Nursing Home is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), as the public water system failed to maintain daily a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. There were 9 days reported on the July 2012 MOR where the system failed to maintain minimum chlorine residuals.

If you have any questions please call your Ohio EPA representative at 614-728-3870 .

Sincerely,

Bridgette Marchio  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

ec: CDO DDAGW Inspector (State Violation)  
eDoc

BM/ct 2400312(MI)Jul2012

**Central District Office**  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)