



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

August 27, 2012

William J. Eitel  
Village of Darbyville  
16671 Main Street  
Williamsport, OH 43164

**Pickaway County  
Village of Darbyville  
COMMUNITY PWS  
PWS ID: OH6503412**

Dear Mr. Eitel:

This letter is notification that the Village of Darbyville public water system is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), as the public water system failed to maintain daily a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. There were 9 days reported on the July 2012 MOR where the system failed to maintain minimum chlorine residuals.

Please take all necessary action to ensure that proper chlorine residuals are maintained throughout the distribution system. If you have any questions please call me at 614-728-3870.

Sincerely,

Bridgette Marchio  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

ec: CDO DDAGW Inspector (State Violation)  
eDoc

BM/ct 6503412(MI)Jul2012

**Central District Office**  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)