



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

August 27, 2012

Mark Anthony
15111 State Route 664 South
Logan, OH 43138

Fairfield County
Hillview MHP
COMMUNITY PWS
PWS ID: OH2302712

Dear Mr. Anthony:

Hillview MHP is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the **minimum required free or combined chlorine residual** in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine. There were 24 days in June and 18 days in July in which the minimum chlorine residual was not maintained.

These violations do not require public notification but Hillview MHP must take immediate action to resolve them. Please review your operations to determine the reason for the exceedances and advise this office as to what corrections will be made within 10 days of the date of this letter. If you have any questions, please call me at 614-728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

ec/pc: James Bennett, Operator of Record
Fairfield County Health Department
IMS, DDAGW, CO
AA, DDAGW, CDO
CDO File
eDoc

CO/ct 2302712(M)Jul2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov