



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

August 29, 2012

Sandra McCoy
6244 London-Groveport Road
Grove City, OH 43123

Franklin County
Community Gardens MHP
COMMUNITY PWS
PWS ID: OH2500512

Dear Ms. McCoy:

Community Gardens MHP is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were 3 weeks during the month of July in which manganese exceeded the secondary standard. Also, the manganese levels have exceeded the secondary standard for at least two weeks out of every month since the chemical feed system was installed early this year.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification but Community Gardens MHP must take immediate action to resolve this violation. Please review your operations to determine the reason for the exceedances and advise this office as to what corrections will be made within 10 days of the date of this letter. We may have no other choice than to take action to enforce this requirement. A civil penalty could be assessed as part of this enforcement action.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

Sandra McCoy
Page -2-

If you have any questions, please call me at 614-728-3864.

Sincerely,



Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

ec/pc: John Kinder, Operator of Record
Franklin County Health Department
IMS, DDAGW, CO
AA, DDAGW, CDO
CDO File
eDoc