



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

August 29, 2012

John Francisco  
P.O. Box 43204  
2000 Bethel Road  
Columbus, OH 43225

Franklin County  
Hayden Heights MHP  
COMMUNITY PWS  
PWS ID: OH2501612

Dear Mr. Francisco:

Hayden Heights MHP is in violation of Ohio Revised Code Chapter 6109 in July, 2012 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for both iron which is 0.3 mg/L and manganese which is 0.05 mg/L. The levels reported for July 2<sup>nd</sup>, exceeded both secondary standards. The level for iron was reported at 6.2 mg/L. The level for manganese was reported at 0.43 mg/L.

Monitoring and compliance determinations for the secondary maximum contaminant levels for iron and manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F) (5) and (F) (6) to determine compliance with the secondary maximum contaminant levels.
- (b) A public water system shall be in violation of the secondary standard for iron or manganese or when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

These violations do not require public notification but Hayden Heights MHP must take immediate action to resolve these violations. Please review your operations to determine the reason for the exceedances and advise this office as to what corrections will be made within 10 days of the date of this letter.

John Francisco  
Page -2-

If you have any questions, please call me at 614-728-3864.

Sincerely,

A handwritten signature in cursive script, appearing to read "Carolyn O'Neal".

Carolyn O'Neal  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

ec/pc: Pat Hickman, Operator of Record, 290 Shepper Avenue, Plain City, OH 43064  
Franklin County Health Department  
IMS, DDAGW, CO  
DDAGW CDO Inspector  
eDoc