



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Henry County
Storm Water
Construction Activity
Permit No. 2GC00835*AG

April 12, 2011

Mr. Steve Sachmann
B Hill'z Excavating
8085 McCutchenville Road
Wayne, Ohio 43466

Dear Mr. Sachmann:

On March 30, 2011, I performed an inspection of the Florida WWTP construction site, located on the east side of County Road 17-C approximately one-half mile south of County Road M. The purpose of this visit was to evaluate compliance of the site with the construction general permit (CGP). The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

Construction activities have been completed with final stabilization achieved on all portions of this site except for two stockpiles of dirt. Once those stockpiles are stabilized, it appears that you will be eligible to terminate this NPDES permit. The CGP requires that a Notice of Termination (NOT) be filed to relieve you of the obligation to comply with the terms and conditions of this general permit including regular inspections of the site. The NOT form and instructions may be found on our website at: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>

If you have any questions, please contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.state.oh.us

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/llr

pc: DSW-NWDO File