



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Huron County
Bob Evans
Construction
Storm Water

July 16, 2009

Mr. Chris Daniel
Bob Evans
3776 South High Street
Columbus, Ohio 43207

Dear Mr. Daniel:

On June 25, 2009, Lynette Hablitzel and I inspected the Bob Evans located at 4800 U. S. Route 250, Norwalk. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity (Construction General Permit), Facility ID No. 2GC02130. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. As a result of this inspection, the site may soon be eligible to terminate NPDES permit coverage.

It appears that construction activities at Bob Evans are complete. Please be aware that a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit, including the obligation of routine inspections. A NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been achieved on all portions of the site for which the permittee is responsible. Final Stabilization means that either:
 1. All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have removed, properly disposed of, and all trapped sediment is permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.



Mr. Chris Daniel
July 16, 2009
Page 2

At the time of our inspection, it was not evident what post construction storm water management practice(s) had been implemented. Please send a written response describing what post construction storm water management practices are being implemented at the site within 10 days of the date on this letter. The permit requires that post-construction Best Management Practices (BMPs) are installed during construction to control pollutants in the storm water discharges that will occur after construction has concluded. Such practices may include, but are not limited to: storm water extended detention structures; retention structures; water quality swales; and bioretention areas. Your reply should include the type(s) of practices and the basis for its design. When a uniform perennial vegetative cover has reached a growth density of 70% across the entire site and all permit conditions have been met, you will be eligible to submit an NOT application form to Ohio EPA's Central Office. The NOT form can be found on our website: <http://www.epa.state.oh.us/dsw/storm/stormform.html>. NOTs must be submitted within 45 days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3085.

Sincerely,



Korey Sarven
Division of Surface Water

//lr

pc: [DSW;NWDO File]
Josh Snyder, Public Works Director