



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Lucas County
ALDI Inc-Oregon
Construction
Storm Water

August 25, 2010

Mr. Kevin McClure
ALDI Inc. Ohio
1319 West 130th Street
Hinckley, Ohio 44233


Dear Mr. McClure:

On July 8, 2010, Sarah Clement and Judson Delancey inspected the ALDI Inc-Oregon on Navarre Avenue in Oregon. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02667*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The Ohio EPA has no record of other permittees at this site.

It appeared that construction had not started. When construction starts, it is important to remember the permit requirements for storm water management during construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven (7) days of grubbing and before any grading. You should refer to Ohio's *Rainwater and Land Development Manual* (ODNR) for the proper installation and maintenance of erosion and sediment control practices.

The permit requires that post-construction Best Management Practices (BMPs) are installed during construction to control pollutants in the storm water discharges that will occur after construction has concluded. Such practices may include, but are not limited to: storm water extended detention structures; retention structures; water quality swales; and bioretention areas. Within 10 days of the date on this letter, please provide in writing a description of the post-construction BMPs that will be installed. Your reply shall include the type(s) of practices and the basis for their design. If there are any questions, please contact me at (419) 373-3009

Sincerely,


Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/llr

pc:  **DSW-NWDO File**
Paul Roman, Director of Public Service

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov