



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korfeski, Director

Re: Lucas County
Bendview Metro Park
Construction
Storm Water

August 25, 2010

Mr. Jon Zvanovec
Metropolitan Park District of the Toledo Area
Fallen Timbers Field Office
6101 Fallen Timbers Lane
Maumee, Ohio 43537

Dear Mr. Zvanovec:

On June 7, 2010, Sarah Clement and Judson Delancey IV inspected Bendview Metro Park in Providence Township. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02625*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The Ohio EPA has no record of other permittees at this site.

Based on information you provided over the phone and staff observations, it appears that construction had not started. When construction begins, it is important to remember the permit requirements for storm water management during construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven (7) days of grubbing and before any grading. You should refer to Ohio's *Rainwater and Land Development Manual* (ODNR) for the proper installation and maintenance of erosion and sediment control practices.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,

Lynette Hablitzel, PE
Division of Surface Water
Storm Water Program

//lr

pc: ~~DSW-NWDO File~~
Jeff Grabarkiewicz, Lucas County SWCD
Keith G. Earley, P.E., P.S.