



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Lucas County
First Alliance Church
Construction
Storm Water

August 16, 2010

Mr. Jason J. Christen
Leantrak Inc
1646 Indian Wood Circle
Suite 101
Maumee, Ohio 43537

Dear Mr. Christen:

On July 26, 2010, I inspected the First Alliance Church at 2201 Monroe Street, Toledo. The purpose of my visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02685*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Ohio EPA has no record of other permittees at this site.

As a result of the inspection and a phone call with Kendra Sankovich, Director of Office Operations for First Alliance Church, on July 28, 2010, at 10:15 AM, I have the following comments:

At the time of inspection, construction had not begun. Construction of a new church will be west of 22nd Street where the old Church used to be. When construction begins, it is important to remember the permit requirements for storm water management during construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven (7) days of grubbing and before any grading. You should refer to Ohio's *Rainwater and Land Development Manual* (ODNR) for the proper installation and maintenance of erosion and sediment control practices. I recommend reading and understanding the *Construction General Permit* before construction begins.

If there are any questions, please contact me at (419) 373-3036.

Sincerely,

Judson M. DeLancey IV
Division of Surface Water
Storm Water Program

//lr

pc: DSW-NWDO File
Patekka Bannister, City of Toledo, Division of Environmental Services

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov