



2GC0265120100825

LUCAS SANITARY SEWER NO. 710

2GC02651 2010/08/25 DELANCEY, JUDSON



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Lucas County
Sanitary Sewer No. 710
Construction
Storm Water

August 25, 2010

Mr. Jim Shaw
Lucas County Sanitary Engineer
1111 South McCord Road
Holland, Ohio 43528

Dear Mr. Shaw:

On June 21, 2010, Sarah Clement and Judson M. Delancey IV inspected the Sanitary Sewer No. 710 site on Kelker Street/Wilford Drive/Blossman Road in Sylvania Township. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02651*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Ohio EPA has no record of other permittees at this site.

It did not appear that construction had started at the time of the inspection. When construction starts, it is important to remember the permit requirements for storm water management during construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven (7) days of grubbing and before any grading. You should refer to Ohio's *Rainwater and Land Development Manual* (ODNR) for the proper installation and maintenance of erosion and sediment control practices.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,

Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

Llr

pc: CDSW-NWDO File
Greg Huffman, Public Works Manager
Keith G. Earley, P.E./P.S.
Jeff Grabarkiewicz, Lucas County SWCD