



\*2GC0233620100825\*

LUCAS      SANITARY SEWER NO. 758      2GC02336 2010/08/25      DELANCEY, JUDSON      HOLLAND



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Lucas County  
Sanitary Sewer No. 758  
Construction  
Storm Water

August 25, 2010

Mr. Jim Shaw  
Lucas County Sanitary Engineer  
1111 S McCord Rd  
Holland, OH 43528

Dear Mr. Shaw:

On June 21, 2010, Sarah Clement and Judson M. Delancey IV inspected the Sanitary Sewer No. 758 project on Dorr Street, near McCord, in Springfield Township. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02336\*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The Ohio EPA has no record of other permittees at this site.

As a result of this inspection, your site may be eligible to terminate your NPDES permit. It appears that construction activities at the site are completed. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

< Final Stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means that:


All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment is permanently stabilized.

< Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

It appears that your site meets the above criteria. If you believe the same is true, please file an NOT form which can be found on our website: <http://epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be submitted to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,

  
Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/lb

pc

**NWDO file**

Leslie Kohli, Administrator, Springfield Twp.  
Keith G. Earley, P.E./P.S., Lucas County Engineer  
Lara Burkett, Administrator, Lucas County SWCD