



2GC0266420100825

LUCAS	WATER SUPPLY LINE NO 941-	2GC02664	2010/08/25	DELANCEY, JUDSON	
	REPLACEMENT				



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korfeski, Director

Re: Lucas County
Water Supply Line No 941-
Replacement
Construction
Storm Water

August 25, 2010

Mr. Jim Shaw
Lucas Co Sanitary Engineer
1111 S McCord Road
Holland, OH 43528

Dear Mr. Shaw:

On July 8, 2010, Sarah Clement and Judson Delancey inspected the Water Supply Line No 941-Replacement in Jerusalem Township. The purpose of the visit was to evaluate compliance with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02664*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Ohio EPA has no record of other permittees at this site.

It did not appear that construction had started at the time of the inspection. When construction starts, it is important to remember the permit requirements for storm water management during construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within 7 days of grubbing and before any grading. You should refer to Ohio's *Rainwater and Land Development Manual* (ODNR) for the proper installation and maintenance of erosion and sediment control practices.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,

Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/lb

pc

Jeff Grabarkiewicz, Lucas SWCD
Keith G. Earley, P.E./P.S., Lucas County Engineer's Office
Dan Sabolsky, Zoning Inspector, Jerusalem Township