



2GC0248420100825

LUCAS IWL-3366 WATER REPLACEMENT 2GC02484 2010/08/25 DELANCEY, JUDSON TOLEDO



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Lucas County
WL-3366 Water Replacement
Construction
Storm Water

August 25, 2010

Ms. Laurie Hasslinger
City of Toledo
600 Jefferson Avenue
#300
Toledo, OH 43604

Dear Ms. Hasslinger:

On July 8, 2010, Sarah Clement and Judson Delancey inspected the WL-3366 Water Replacement on Dorr Street, between Flaire Drive and Richards Road, Toledo. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02484*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Ohio EPA has no record of other permittees at this site.

It did not appear that construction had started at the time of the inspection. You confirmed this during a July 9, 2010, phone call with Judson.

When construction starts, it is important to remember the permit requirements for storm water management during construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within 7 days of grubbing and before any grading. You should refer to Ohio's *Rainwater and Land Development Manual* (ODNR) for the proper installation and maintenance of erosion and sediment control practices.

If there are any questions, please contact me at (419) 373-3009

Sincerely,

Lynette Hablitzel, PE
Division of Surface Water
Storm Water Program

/lb

pc

 Patekka Bannister, City of Toledo, Division of Environmental Services