



2GC0093920110817

MARION	ODOT MARION CO MAINTENANCE FACILITY	2GC00939	2011/08/17	DELANCEY, JUDSON	MARION
--------	-------------------------------------	----------	------------	------------------	--------



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Marion County
ODOT Marion Co. Maintenance Facility
Construction
Storm Water

August 17, 2011

Mr. Bruce Ratekin
Ohio Department of Administrative Services
4200 Surface Drive
Columbus, Ohio 43228

Dear Mr. Ratekin:

On June 15, 2011, Ohio EPA representative Judson Delancey inspected the ODOT Marion County Maintenance Facility at 1775 East Marion-Williamsport Road, Marion Township. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC00939*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that the construction activities at the ODOT Marion County Maintenance Facility are near completion and that a retention pond has been installed as the post construction storm water management practice. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


- Final stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means either that:
 1. All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
 2. For construction projects on land used for agricultural purposes, final stabilization may be accomplished by returning the disturbed land to its pre-construction agricultural use. If not returned to its pre-construction agricultural use, the land must meet the final stabilization criteria in (1).
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Bruce Ratekin
August 17, 2011
Page Two

Your site appears to meet the above criteria. If you also believe this to be true, please file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.html>. NOTs must be filed with Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,



Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

JD/jlm

pc: Bradley Irons P.E., P.S., Marion County Engineer
Marion County SWCD
NWDO Files ~