



2GC0020720110819

MARION	OSU MARION STUDENT SERVICES	2GC00207	2011/08/19	DELANCEY, JUDSON	MARION
	BLDG & PARKING				



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Marion County
OSU Marion Student Services Building
& Parking
Construction
Storm Water

August 19, 2011

Mr. Don Lair
Ohio State University-Marion Campus
1465 Mount Vernon Avenue
Marion, Ohio 43302

Dear Mr. Lair:

On June 15, 2011, Ohio EPA representative Judson Delancey inspected the OSU Marion Student Services Building and Parking at 1465 Mount Vernon Avenue, Marion Township. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC00207*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that the construction activities at the OSU Marion Student Services Building and Parking are near completion. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means either that:
 1. All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
 2. For construction projects on land used for agricultural purposes, final stabilization may be accomplished by returning the disturbed land to its pre-construction agricultural use. If not returned to its pre-construction agricultural use, the land must meet the final stabilization criteria in (1).
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.


Mr. Don Lair
August 19, 2011
Page Two

Your site appears to meet the above criteria. If you also believe this to be true and have installed the required post-construction storm water management facilities, please file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be filed with Ohio EPA's Central Office within 45 days of when the above criteria are met.

The permit requires that post-construction Best Management Practices (BMPs) be installed during construction to control pollutants in the storm water discharges that will occur after construction has concluded. Such practices may include, but are not limited to: storm water extended detention structures; retention structures; water quality swales; and bioretention areas. Please send a written reply within ten days of the date of this letter describing how this requirement will be met. Your reply should include the type(s) of practices you are implementing, the basis for their design, and installation dates.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,



Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

JD/jlm

pc: Bradley Irons P.E., P.S., Marion County Engineer
Marion County SWCD
Charles Fosnaugh, Marion Township Zoning Inspector
NWDO File