




**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott C. Ostby, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

September 10, 2012

Re: Licking County  
Papa Boo's  
Transient Water System  
PWS ID: OH4531412  
TP ID: 4555553

Mr. Jason Biggs  
Owner  
Papa Boo's  
1424 Tiki Lane  
Lancaster, OH 43130

Dear Mr. Biggs:

The Public Water System serving Papa Boo's is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

*This letter is notification that the Papa Boo's PWS has not complied with requirements issued during this Agency's last survey performed on May 21, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated June 20, 2012 to respond in writing no later than 30 days, with time frames for:*

1. Once you have picked out an alternate lab, fill out the attached sample siting plan and maintain it on site, and send a copy of the first page to this office.
2. Post the attached public notice to abate an outstanding violation. Fill out the front before posting, leave it up for 10 days, then fill out the back and send copies to this office.
3. Fasten the well cap securely and keep it fastened. This was a requirement of last survey (in 2006). Remove the trash can from the well head area. Chase suggested placing by the outdoor ice machine, I agreed that would be fine.
4. Ensure the use of NSF or ANSI approved salt in your softener. Look for one of the two logos on the containers or confirm with your supplier or the manufacturer.

**Central District Office**  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

Mr. Jason Biggs  
Papa Boo's  
Page -2-

5. Provide information on who you are obtaining water from and where the water is coming from. I understand that during heavy weekends, when the population may go over 900 on a busy Friday or Saturday night, water is sometimes ordered and placed into the outside storage tanks as your well does not produce enough water to meet demand.
6. Replace the broken pressure gauges both downstairs in the main treatment room and outside adjacent to the four plastic tanks. Also replace the cap to the outside pressure switch and keep it installed. 20 amp circuits are exposed at this location.
7. As you did in 2002 when the plastic tank inside the building was installed, submit detail plans for the 4 outside tanks and pressure tank discovered during this survey. A set of blank plans are enclosed for your use. In the future, do not make any substantial changes to your public water system without prior approval from this office. This includes making any changes to your source, treatment or storage facilities associated with the public water system.
8. Obtain a well log for your well (logs turned into the Department of Natural Resources, as required by law, are found online at):  
<http://www.dnr.state.oh.us/water/maptechs/wellogs/appNEW/> or fill out the attached well construction worksheet using a current state registered driller. Casing length cannot be estimated. Registered drillers can be located at:  
<http://www.odh.ohio.gov/~media/ODH/ASSETS/Files/eh/water%20systems%20private/listofregisteredprivatewatercontractorslocatedinohio.ashx>.
9. Let me know if a working water meter is still in use at your system. If so, what does it currently read? I did not observe one during this survey but it appears one used to be installed.

If you have any questions, please contact your Ohio EPA representative at 614 728 3871 or via email at [mark.boden@epa.state.oh.us](mailto:mark.boden@epa.state.oh.us).

Sincerely,



Mark Boden  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

ec: CDO/DDAGW AA (State Violation)  
eDoc