



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

September 6, 2012

Dana Milligan  
4242 Tuller Road  
Suite B  
Dublin, OH 43017

Licking County  
El Rancho Mobile Home Park  
Community Water System  
PWS ID # OH4500512

Dear Ms. Milligan:

This letter is notification that the El Rancho Mobile Home Park is in violation of OAC 3745-83-01 (F)(2) for July 2012, as the public water system failed to report chlorine residual (free or combined) daily at the plant tap and distribution system. There were 4 days during the month in which the analysis was not performed.

This violation does not require public notification. However, please review your operations to determine the reason for the missing analyses and advise this office as to what corrections will be made.

Also, please note the water treatment plant production values are to be entered in millions of gallons per day (MGD). Please ensure the future entries are entered properly.

If you have any questions, please contact me directly at (614) 728-3863.

Respectfully,

Katie A. Anderson, E.I.  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

c: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
CDO File

ec: CDO DDAGW Inspector (State Violation)  
eDoc

KA/vcl 4500512(Mi)Jul2012

**Central District Office**  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)