




**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

September 6, 2012

Robert F. Toland
55 Dewmar Drive
Heath, OH 43056-9641

Licking County
Suburban Mobile Home Park
COMMUNITY PWS
PWS ID: OH4502812

Dear Mr. Toland:

This letter is notification that the Suburban Mobile Home Park is in violation of OAC 3745-83-01 (F)(2) for July 2012, as the public water system failed to report chlorine residual (free or combined) daily at the plant tap and distribution system. There were 9 days during the month in which the analysis was not performed.

This violation does not require public notification. However, please review your operations to determine the reason for the missing analyses and advise this office as to what corrections will be made.

If you have any questions, please contact me directly at (614) 728-3863.

Respectfully,

Katie A. Anderson, E.I.
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

c: Toni Buchanan, Ohio EPA, Central Office, DDAGW
CDO File

ec: CDO DDAGW Inspector (State Violation)
eDoc

KA/ct 4502812(MI)Jul2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov