



**Environmental  
Protection Agency**

John E. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



**NOTICE OF VIOLATION – ACTION REQUIRED**

September 6, 2012

Dave Carnevale  
Ranco North America LP  
P.O. Box 133  
Plain City, OH 43064

**Union County  
Non-Transient Non-Community Water System  
PWS ID # OH8033512**

Dear Mr. Carnevale:

This letter is notification that Ranco North America LP is in violation of OAC 3745-83-01 (C)(1) for July 2012, as the public water system failed to maintain the minimum required (free/combined) chlorine residual in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than (two-tenths milligram per liter free chlorine / one milligram per liter combined chlorine). There were eight days during the month in which the minimum chlorine residual was not maintained.

This violation does not require public notification. However, please review your operations to determine the reason for the missing analyses and advise this office as to what corrections will be made.

If you have any questions, please contact me directly at (614) 728-3863.

Respectfully,

Katie A. Anderson, E.I.  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

c: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
CDO File

ec: CDO DDAGW Inspector (State Violation)  
eDoc

KA/ct 8033512(MI)Jul2012

**Central District Office**  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
www.epa.ohio.gov