



**Environmental  
Protection Agency**

Jon R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Kelly, **Director**



**NOTICE OF VIOLATION – ACTION REQUIRED**

August 30, 2012

Ashley Gleason  
2101 E Coast Highway  
Suite 110  
Corona Del Mar, CA 92625

Pickaway County  
Caravan Village MHP  
COMMUNITY PWS  
PWS ID: OH6503312

Dear Public Water System Owner:

The Public Water System serving CARAVAN VILLAGE MHP is in violation of the Ohio Administrative Code (OAC) for failure to maintain adequate chlorine residuals within the distribution system during July 2012.

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. According to the July 2012 monthly operating report, the chlorine residual was too low for 11 days during the month. Each occurrence is a violation of OAC 3745-83-01.

These violations do not require public notification but Caravan Village MHP must take immediate action to resolve these violations. Please review your operations to determine the reason for the inadequate chlorine residuals and advise this office as to what corrections have or will be made within 10 days of the date of this letter.

If you have any questions please call me at 614-728-3870.

Sincerely,

Bridgette Marchio  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

c: Pickaway County Health Department  
Steve Sherrick, Operator, Caravan Village MHP  
ec: CDO DDAGW Inspector (State Violation)  
eDOC

BM/ct 6503312(MI),July2012

**Central District Office**  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)