



\*2GC0265020100827\*

PUTNAM .2007 WATERLINE REPLACEMENT |.2GC02650| 2010/08/27 | DELANCEY, JUDSON | CONTINENTAL



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Putnam County  
2007 Waterline Replacement  
Construction  
Storm Water

August 27, 2010

The Honorable Terry Dockery  
Mayor of the Village of Continental  
100 North Main Street  
P. O. Box 447  
Continental, Ohio 45831

Dear Mayor Dockery:

On July 22, 2010, Judson Delancey inspected the 2007 Waterline Replacement north of Elm Street in Continental and along Rice Street in Continental. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02650\*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Ohio EPA has no record of other permittees at this site.

The Village did not appear to have started construction. This was confirmed during Judson's July 28, 2010, phone call with you.

When construction does begin, it is important to remember the permit requirements for storm water management during construction and post construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven (7) days of grubbing and before any grading. You should refer to Ohio's *Rainwater and Land Development Manual* (ODNR) for proper installation and maintenance of erosion and sediment control practices.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,

Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/lir

pc: DSW-NWDO-File