



2GC0232420100816

PUTNAM BROAD STREET RECONSTRUCTION 2GC02324 2010/08/16 DELANCEY, JUDSON KALIDA



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Putnam County
Broad Street Reconstruction
Construction
Storm Water

August 16, 2010

The Honorable Alan Gerdeman
Mayor of the Village of Kalida
P. O. Box 485
Kalida, Ohio 45853

Dear Mayor Gerdeman:

On July 27, 2010, Sarah Clement and I inspected the Broad Street Reconstruction in Kalida, Putnam County. The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02324*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Ohio EPA has no record of other permittees for this site.

As a result of the inspection you may be eligible to terminate your NPDES permit coverage for this site. It appears that all construction activities at the site are completed. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. A NOT may be filed if one or more of the following conditions have been met:

- < Final stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means either:
 1. All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment is permanently stabilized.
 2. For construction projects on land used for agricultural purposes, final stabilization may be accomplished by returning the disturbed land to its pre-construction agricultural use. If not returned to its pre-construction agricultural use, the land must meet the final stabilization criteria above.

The Honorable Alan Gerdeman
August 16, 2010
Page 2


< Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

It appears that your site meets the above criteria. If you believe the same is true and you have met all permit conditions, please file the NOT form. The NOT form and instructions can be found on our website:

<http://epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be submitted to Ohio EPA's Central Office within forty five days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3036.

Sincerely,



Judson M. Delancey IV
Division of Surface Water
Storm Water Program

/llr

pc: DSW-NWDO-File
Putnam County SWCD