





**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

Re: Wood County
Twin Maples MHP
Community Water System
PWS ID # OH8702712

August 23, 2012

Mr. Emil Dean
Twin Maples MHP
30266 Bradner Road
Northwood, Ohio 43619

Dear Mr. Dean:

This letter will confirm removal of the water use advisory required in our letter dated August 15, 2012. This is based on one set of four total coliform negative (safe) samples collected on August 10, 2012.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by September 6, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of August 2012.

Yours truly,

Jill A. Schiefer
Division of Drinking and Ground Waters

/llr

pc: Wood County Health Department
DDAGW, NWDO

