



\*2GC0250620100827\*

---

RICHLAND | AM COMMUNICATIONS

| 2GC02506 2010/08/27 DELANCEY, JUDSON &nbsp;



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Richland County  
AM Communications  
Construction  
Storm Water

August 27, 2010

Mr. Alan Miller  
AM Communications  
PO Box 212  
Ontario, OH 44862

Dear Mr. Miller:

On June 16, 2010, Sarah Clement and Judson M. Delancey IV inspected AM Communications at 5707 SR 309 in Sandusky Township. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02506\*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Ohio EPA has no record of other permittees at this site.

As a result of this inspection, you may be eligible to terminate NPDES permit coverage for this site. It appears that construction activities at the site are near completion. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- < Final Stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means that either:
  1. All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment is permanently stabilized; or
  2. For construction projects on land used for agricultural purposes, final stabilization may be accomplished by returning the disturbed land to its pre-construction agricultural use. If not returned to its pre-construction agricultural use, the land must meet the final stabilization criteria in (1) above.
  
- < Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.


Mr. Alan Miller  
August 27, 2010  
Page Two

It appears that your site meets the above criteria. If you believe the same is true and you have installed the project's post construction storm water Best Management Practices (BMPs), please file the NOT form. The NOT form can be found on our website: <http://epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be submitted to Ohio EPA's Central Office within 45 days of when the above criteria are met.

The permit requires that post-construction Best Management Practices (BMPs) are installed during construction to control pollutants in the storm water discharges that will occur after construction has concluded. Such practices may include, but are not limited to: storm water extended detention structures; retention structures; water quality swales; and bioretention areas. Within 10 days of the date on this letter, please provide in writing a description of the post-construction BMPs that will be installed. Your reply shall include the type(s) of practices, the basis for their design, and their installation dates.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,



Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/lb

pc **NWDO file**  
Richland County SWCD  
Thomas E. Beck, P.E., P.S., Richland County Engineer