



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



September 5, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Jon Updegraff
Blue Room Tavern
129 South Main Street
P. O. Box 21
Kirby, Ohio 43330

Wyandot County
Blue Room Tavern
Transient Non-Community PWS

PWS ID: OH8830412

Dear Mr. Updegraff:

The Public Water System serving Blue Room Tavern is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that the Blue Room Tavern Public Water System has not complied with requirements issued during this Agency's last survey performed on July 19, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated July 23, 2012, to respond in writing no later than 30 days, with time frames for:

1. OAC Rule 3745-9-05 (P) states, "A well cap for a public water system well shall conform with "Water System Council Pitless Adapter Standard PAS-97, Performance Standards for Sanitary Water Well Pitless Adapters, Pitless Units, and Watertight Well Caps (1997).

The well cap shall be replaced with one that includes an integrated, screened vent and a threaded conduit connection.

2. OAC Rule 3745-95-05 (A) (1) requires an approved air gap separation to be installed where a public water system may be contaminated with substances that could cause a severe health hazard. The drain line from the softener was not isolated from the waste water line.

Install an appropriate air gap in the drain line to isolate the drinking water from the waste water line.

Mr. Jon Updegraff
September 5, 2012
Page 2

If you have any questions, please contact me at 419-373-3101.

Sincerely,

A handwritten signature in black ink, appearing to read "C. Riddle". The signature is fluid and cursive, with the first name "C." and the last name "Riddle" clearly distinguishable.

Chris Riddle
Division of Drinking and Ground Waters

/lir

pc: DDAGW – NWDO