





**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

Re: Sandusky County
Shorewood Village Subdivision
Community PWS
PWS ID: OH7201012
STU ID: 7257906

July 31, 2012 NOV Rescission

September 10, 2012

Mr. Steven F. Shiets
Shorewood Village Subdivision
2100 Countryside Place
Fremont, Ohio 43420

Dear Mr. Shiets:

On July 31, 2012, this office issued a notice of violation to the Shorewood Village Subdivision that cited a violation of Ohio Administrative Code (OAC) Rule 3745-82-02, for exceeding the secondary standard for iron during the month of June 2012. On August 14, 2012, Operator of Record Tom Frey telephoned me to discuss the appropriate response to the violation.

Review of OAC Rule 3745-83-01(F)(5) finds that monitoring for iron is not required for the Shorewood Village Subdivision public water system. OAC Rule 3745-83-01(F)(5) states in pertinent part:

(5) Iron.

*A community public water system that **provides treatment to reduce iron** shall monitor for iron at least at each entry point to the distribution system. **[emphasis added]***


The public water system serving Shorewood Village Subdivision feeds a polyphosphate solution to sequester iron, which is not a treatment that is intended to reduce iron. Therefore monitoring for iron is not required to be conducted or reported for this public water system.

Our notice of violation letter dated July 31, 2012, is hereby rescinded.

Mr. Steven F. Shiets
September 10, 2012
Page 2

If you have any questions regarding this letter, please contact me at 419-373-3102 or via email at Kim.Burnham@epa.state.oh.us . If you have any other questions concerning your public water system, please contact Janis D'Amico at 419-373-3108 or via email at Janis.Damico@epa.state.oh.us.

Sincerely,



Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

/llr

pc: Sandusky County Health Department
Thomas Frey, Sandusky County Sanitary Engineer Department
File: DDAGW – NWDO

ec: Janis D'Amico, DDAGW – NWDO