



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

Re: Lucas County
Big Sandy Campground
TNC Water System
PWS ID # OH4837812

September 12, 2012

Mr. Ed Foley
Big Sandy Campground
4035 South Berkey-Southern Road
Swanton, Ohio 43558


Dear Mr. Foley:

This letter will confirm removal of the water use advisory required in our letter dated August 31, 2012. This is based on one set of four total coliform negative (safe) samples collected on September 5, 2012.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by September 26, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of September 2012.

Yours truly,



Curtis Eldridge
Division of Drinking and Ground Waters

/s/

pc: Lucas County Health Department
DDAGW, NWDO

(

(

11.11.11

11.11.11