





**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott L. Nally, **Director**

Re: Putnam County  
American Legion Post 715  
TNC Water System  
PWS ID # OH 6944612

September 12, 2012

Mr. Doyle Wittler  
American Legion Post 715  
100 Legion Drive  
P. O. Box 37  
Fort Jennings, Ohio 45844

Dear Mr. Wittler:

This letter will confirm removal of the water use advisory required in our letter dated September 11, 2012. This is based on one set of four total coliform negative (safe) samples collected September 5, 2012, and received by our office September 11, 2012.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by September 26, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of September 2012.

Yours truly,

Clayton McKee  
Division of Drinking and Ground Waters

/llr

pc: Putnam County Health Department  
DDAGW, NWDO

(

)

...

...