



\*2GC0231120100729\*

SANDUSKY CLYDE HIGH SCHOOL

2GC02311 2010/07/29 CLEMENT, SARAH

CLYDE



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Sandusky County  
Clyde High School  
Construction  
Storm Water

July 28, 2010

Mr. Greg Elchert  
Clyde-Green Springs Exempted Village School District  
106 South Main Street  
Clyde, Ohio 43410

Dear Mr. Elchert:

On July 6, 2010, Judson Delancey and I inspected Clyde High School at 1015 Race Street in Clyde. The purpose of our inspection was to evaluate compliance of the site with your National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge associated with construction activity, Facility ID No 2 GC02311\*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Troy Overmyer, Superintendent for Mosser Construction, Inc., was present to provide information on the project.

Ohio EPA has not received a Co-Permittee Notice of Intent (NOI) for this project. This form is used by construction site operators, as defined in Part VII.O. of the Construction General Permit, to become co-permittees with the initial permittee of a construction site. Please note that Part II.A. of the Construction General Permit (CGP) **requires all operators at a construction site to become co-permittees**. If you have a contractor responsible for the day to day operation of the site, implementing the Storm Water Pollution Prevention Plan, they must obtain permit coverage. Copies of the Co-Permittee NOI may be downloaded from our website: <http://www.epa.ohio.gov/dsw/storm/index.html>.

As a result of the inspection, I have the following comments:

1. At the time of the inspection the exterior construction on the existing school building had been completed. A dozer was onsite and final grading was in process. The drive on the east side of the building, off of Race Street, was gravel; however Mr. Overmyer informed us the drive was to be paved the following day. On the west side of the site, by Woodland Avenue, there were top soil stock piles.
2. A Storm Water Pollution Prevention Plan (SWP3) had been developed for the site and was available.
3. Inspections logs were kept and appeared to have been conducted weekly and within 24 hours of a 0.5 inch or greater rainfall.

Mr. Greg Elchert  
July 28, 2010  
Page Two

4. The storm drain inlets in the drive off of Race Street did not have inlet protection. Mr. Overmyer explained that they had been removed in anticipation of paving the drive the following day. *Permit Requires:* Practices shall minimize sediment laden water entering active storm drain systems unless they drain to a sediment settling pond. All sediment control practices must be maintained in a functional condition until all upslope areas that they control are permanently stabilized. *This is a violation of Parts III.G.2.d.iv. of the permit.*
5. The top soil stock piles on the west side of the site and the bare areas around the drive on the east side of the site were not stabilized. As construction continues please keep in mind the permit requirements about temporary and permanent stabilization. *Permit Requires:* Portions of the construction site that will remain inactive for more than 21 days must have temporary stabilization initiated within the first seven days. Permanent stabilization is required within seven days on any portion of the site that has reached final grade or will be idle for longer than one year. Permanent seeding and mulching is required before construction activity is completed throughout the entire site. If seasonal conditions prohibit the establishment of vegetative cover, other means, such as mulching and matting, must still be used and maintained until more permanent methods can be implemented. *Please see Part III.G2.b.i. of the permit.*

Please send written notification of what corrective measures you have taken within 10 days of the date on this letter. Your response should include the dates, either actual or proposed, for the completion of the actions.

If there are any questions, please contact me at (419) 373-3025.

Sincerely,



Sarah Clement  
Division of Surface Water  
Storm Water Program

/lb

Pc ~~NWDO File~~  
Don Ball, Environmental Services Superintendent, City of Clyde