



2GC0283420110527

SANDUSKY FOOS FUNERAL & CREMATION
SERVICES

2GC02834 2011/05/27 TEBBE, PATRICIA CLYDE



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Sandusky County
Foos Funeral Home
Construction
Stormwater

May 27, 2011

Mr. Brian Foos
Foos Funeral, LLC
151 Yorkshire Place
Bellevue, Ohio 44811

Dear Mr. Foos:

On April 6, 2011, I inspected the Foos Funeral & Cremation Services site at 515 McPherson Highway in the City of Clyde, Ohio. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID #2GGC02834*AG. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111.

At the time of the inspection, it appeared that no construction activities had begun at the Foos Funeral & Cremation Services site. When construction does begin, it is important to remember the permit requirements for storm water management during construction and post construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within 7 days of grubbing and before any grading. You should refer to Ohio's *Rainwater and Land Development Manual* (ODNR) for proper installation and maintenance of erosion and sediment control practices

If you have any questions, please contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.state.oh.us.

Sincerely,

Patricia A. Tebbe, PE
Division of Surface Water

/cs

pc: (DSW-NWDO File)
James R. Moyer, P.E., P.S., County Engineer
Sandusky County SWCD