



2GC0228520100203

SANDUSKY INEW MIDDLE SCHOOL

2GC02285 2010/02/03 TEBBE, PATRICIA CLYDE



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Sandusky County
Clyde Green Springs Middle School
Construction
Storm Water

February 3, 2010

Mr. Gregg Elchert
Clyde Green Springs Exempted Villages School
106 S. Main Street
Clyde, Ohio 43410

Dear Mr. Elchert:

On January 21, 2010, you and I made an inspection of the Clyde-Green Springs Middle School located at 4230 Limerick Rd, Clyde. The purpose of this inspection was to evaluate compliance of the site with your National Pollutant Discharge Elimination System (NPDES) Permit for storm water associated with construction activity, Construction General Permit (CGP) Facility ID NO. 2GC02285*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. As a result of this inspection, the following are observations or violations of the NPDES permit:

1. The construction entrance is not adequate to keep sediment on the site especially during wet weather. *This is a violation of Part III.G.2.b.of the CGP.*
2. Silt fence located on the west side of the property is not properly joined. Ends of the silt fence are to be twisted together in order to provide a continuous line of silt fence.
3. A sanitary manhole on the east side of the building appeared to have its top ring and cover pushed off the manhole which left an opening allowing sediment and storm water to enter the sanitary sewer. This will need to be repaired and the manhole marked and/or isolated to protect the manhole from equipment in the future.
4. Areas of the site along the south side did not have temporary or permanent seeding established. The permit requires that portions of the construction site which will be inactive for more than 21 days must have temporary stabilization initiated within the first seven days.

Mr. Gregg Elchert
February 3, 2010
Page 2

Permanent stabilization is required within seven days on any portion of the site that has reached final grade or will be idle for longer than one year. If seasonal conditions prohibit the establishment of vegetative cover, other means, such as mulching and matting, must still be used and maintained until more permanent methods can be implemented. *This is a violation of Part III.G.2.b of the CGP.*

The school will utilize the City of Clyde's stormwater pond which is located north of the school's property for post-construction controls.

If you have any questions, you may contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.state.oh.us.

Sincerely,



Patricia A. Tebbe, P.E.
Division of Surface Water

//lr

pc: ~~DSW-NWDO~~ File 
City of Clyde Engineering
Sandusky SWCD