



**Environmental
Protection Agency**

John R. Kasich, **Governor**

Mary Taylor, **Lt. Governor**

Scott J. Nally, **Director**

September 13, 2012

RE: **NOTICE OF VIOLATION**
SUMMIT COUNTY
PINE MILL RIDGE #515 PWS
COMMUNITY WATER SYSTEM
PWS ID # OH7709212

Ms. Renee Hambach
789 W. Lafayette Road
Medina, OH 44256

CERTIFIED MAIL

Dear Ms. Hambach:

This letter is notification that the Pine Mill Ridge #515 public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Pine Mill Ridge #515 PWS as reported on Monthly Operating Report (MOR) #5002 for July 2012. Results reported on the form indicated two (2) days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual. In addition, the free chlorine residual must be monitored at least once every day that water is available to the public at the entry point to the distribution system and a representative point in the distribution system. In July 2012, there were twenty-four (24) days where free chlorine residual results were not collected.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer within 30 days of the date of this letter.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Mark Welton, Operator of Record

ec: Kim Eters, Ohio EPA, DDAGW-DW, NEDO