



\*2GR0042820100603\*

WILLIAMS ALLIED MOULDED PRODUCTS INC 2GR00428 2010/06/03 TEBBE, PATRICIA BRYAN



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Williams County  
Allied Moulded Products, Inc.  
Industrial Storm Water

June 2, 2010

Mr. Ron Clark  
Safety and Environmental Coordinator  
Allied Moulded Products, Inc.  
222 N. Union St.  
P.O. Box 587  
Bryan, Ohio 43506

Dear Mr. Clark:

On April 9, 2010, a stormwater compliance inspection was made of the Allied Moulded Products, Inc. (AMP) in Bryan, Williams County to determine compliance with the National Pollutant Discharge Elimination System General Permit for Storm Water Associated with Industrial Activity (IGP) issued to AMP. The inspection consisted of a tour of the grounds outside of this facility and a review of the Stormwater Pollution Prevention Plan (SWP3).

During the outside inspection I only observed two areas of concern. A rolloff with metal scrap is not covered and is placed near a catch basin. It should be reaffirmed that the area where the roll off is placed does not drain to the catch basin. There is a trench drain outside of the receiving area which receives drainage from trucks. This drain was full of sediment and should be cleaned out. A spill kit is maintained in this area.

A review of the SWP3 indicates that the SWP3 has been recently revised. Please make sure that the contacts for spills and other emergencies are kept up to date.

The IGP is set to expire on May 31, 2011. You may wish to check our website at <http://www.epa.ohio.gov/dsw/storm/index.aspx>. periodically for any updates on the IGP renewal. Once the IGP is drafted and ready for public comment it will be available for viewing on our website.

If you have any questions, you may contact me at (419) 373-3016 or by e-mail at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us).

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/lb

pc: **DSW-NWDO:file**