



2GC0247620100722

WILLIAMS	LIFE CHANGING REALITIES	2GC02476	2010/07/22	DELANCEY, JUDSON	EDGERTON
	FELLOWSHIP				



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Williams County
Life Changing Realities Fellowship
Construction
Storm Water

July 22, 2010

Mr. Bob Unger
Life Changing Realities Fellowship
428 West Vine Street
Edgerton, Ohio 43517

Dear Mr. Unger:

On June 28, 2010, Sarah Clement and I inspected Life Changing Realities Fellowship at 428 W Vine St, Edgerton, in Williams County. The purpose of our visit was to evaluate compliance of the site with your National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge associated with construction activity, Facility ID No. 2GC02476*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The Ohio EPA has no record of other permittees at this site.

As a result of this inspection you may be eligible to terminate your NPDES permit for this site. It appears that construction activities at the site are completed. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. A NOT may be filed if one or more of the following conditions have been met:

- < Final stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means that either:
1. All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control reassures have been removed, properly disposed of, and all tapped sediment is permanently stabilized.
 2. For construction projects on land used for agricultural purposes, final stabilization may be accomplished by returning the disturbed land to its pre-construction agricultural use. If not returned to its pre-construction agricultural use, the land must meet the final stabilization criteria in (1) above.

Mr. Bob Unger
July 22, 2010
Page 2

< Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.


At this time it appears that you are waiting for the 70% density to be established over the entire site. I do have one comment concerning the flow to the detention pond located east of the building. This pond was designed with no inlet structure with water to sheet flow into the pond. However, there appears to be a concentrated flow from the parking lot into the pond that is causing erosion. *Part III.G.2.b.ii* of the NPDES permit requires permanent stabilization of conveyance channels. You will need to install permanent stabilization in order to protect this area from erosion. You may wish to consult the *Rainwater and Land Development* manual for information on how to achieve this. The manual may be found online at:

<http://www.dnr.state.or.us/water/rainwater/default/tabid/9186/default.aspx>.

Once there is a vegetative cover of 70% density and the erosion due to concentrated flow has been fixed you will be eligible to file a NOT for this site. The NOT can be found on our website at: <http://epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be submitted to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3036.

Sincerely,



Judson M. Delancey IV
Division of Surface Water
Storm Water Program

//lr

pc: DSW-NWDO File
Dale A. Mathys, Village Administrator
Williams County SWCD