



2GC0000520100429

WILLIAMS MAPLE LANE ADDITION

2GC00005 2010/04/29 TEBBE, PATRICIA EDGERTON



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Williams County
Storm Water Construction Activity
Maple Lane Addition
Permit No. 2GC00005*AG

April 29, 2010

Mr. Bill Lutterbein
Building Concepts
444 North Michigan Avenue
Edgerton, Ohio 43517

Dear Mr. Lutterbein:

On March 24, 2010, I performed an inspection of the Maple Lane Addition, located southwest of State Route 49 in the Village of Edgerton, Williams County. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of the inspection there was no active construction. There are still several unimproved lots available for sale with all unimproved lots appearing to have been stabilized.

If a lot should be developed, please be sure that sediment and erosion controls are in place before construction is begun. These controls should include proper construction entrances, inlet protection, proper placement of silt fence, and a proper outlet structure of the storm pond, among others.

If there are any questions, please contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.state.oh.us

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/llr

pc: DSW:NWDO-File

