



\*2GC0021720100429\*

WILLIAMS MONTPELIER WTP

2GC00217 2010/04/29 TEBBE, PATRICIA

MONTPELIER



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Williams County  
Storm Water Construction Activity  
Montpelier WTP  
Permit No. 2GC00217\*AG

April 28, 2010

Ms. Pamela Lucas  
PO Box 148  
Montpelier, OH 43543

Dear Ms. Lucas:

On March 24, 2010, I performed an inspection of Montpelier Water Treatment Plant (WTP) at 333 Porter Rd, Montpelier. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. As a result of this inspection, your site may be eligible to terminate your National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity as soon as the site reaches 70% coverage of permanent vegetation in all areas of the site.

It appears that construction activities at the Montpelier WTP are complete. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if final stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site, all temporary erosion and sediment control measures have been removed and properly disposed of, and all trapped sediment is permanently stabilized.

The NOT is to be filed with Ohio EPA's Central Office. The NOT form and instructions may be found on our website at: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>

If there are any questions, please contact me at (419) 373-3016 or by e-mail at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us)

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/lb

pc: ~~NWDO file~~