



2GC0166420090717

WILLIAMS	STRYKER MIDDLE SCHOOL AND HIGH SCHOOL	2GC01664 . 2009/07/17	MEIENBURG, DANIELLE	STRYKER
----------	---------------------------------------	-----------------------	------------------------	---------



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Williams County
Stryker Middle School and High
School
Construction
Storm Water

July 17, 2009

Stryker Local School District
Mr. Russ Griggs
400 South Defiance Street
Stryker, Ohio 43557

And

Baker Shindler Contracting Co. Inc.
Mr. Doug Shindler
525 Cleveland Avenue
P.O. Box 488
Defiance, Ohio 43512

Dear Mr. Griggs and Mr. Shindler:

On July 2, 2009, I inspected Stryker Middle School and High School at 400 South Defiance Street, in Stryker (pictures taken). The purpose of my visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity (Construction General Permit), Facility ID No. 2GC01664. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

As a result of the inspection, I have the following comments:


1. At the time of inspection, the site was inactive. The sidewalks, curbs, utilities, and parts of the parking lot had all been installed. Some roofing work was being done on the building.
2. The ground appeared to have recently reached final grade. *Permit Requires:* Portions of the construction site which will be inactive for more than 21 days must have temporary stabilization initiated within the first seven. **Permanent stabilization is required within 7 days on any portion of the site that has reached final grade** or will be idle for longer than 1 year. Permanent seeding and mulching is required before construction activity is completed throughout the entire site. If seasonal conditions prohibit the establishment of vegetative cover, other means, such as mulching and matting, must still be used and maintained until more permanent methods can be implemented. *Please see Part III.G.2.b.i. of the permit.* At a minimum, temporary stabilization must be applied to bare idle areas of the site.

Mr. Russ Griggs
Mr. Doug Shindler
July 17, 2009
Page Two

I recommend applying a cover of straw mulch at 2 tons per acre, using a disc or a tackifier. This method would need to be maintained until fall, when weather conditions are suitable for seeding.

At this time the site appears to be in compliance with the permit. If there are any questions, please contact me at (419) 373-3006.

Sincerely,



Danielle Meienburg
Division of Surface Water
Storm Water Program

/lb

pc ~~NWDG:File~~
Gary St. John, Village of Stryker