



\*2GC0123620100326\*

---

WOOD	FACILITY FOR HOME DELIVERED - CONGREGATE MEALS	2GC01236 2010/03/26	TEBBE, PATRICIA	BOWLING GREE
------	---	---------------------	-----------------	--------------



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Wood County  
Storm Water  
Construction Activity  
Permit No. 2GC01236\*AG

March 22, 2010

Mr. Jerry Voll  
Duket Porter Assoc.  
830 Summit St.  
Toledo, OH 43604

Dear Mr. Voll:

On March 19, 2010, I performed an inspection of Facility for Home Delivered Congregate Meals, at 1860 E. Gypsy Lane Rd, Bowling Green, Wood County. The purpose of my visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. As a result of this inspection, your site may be eligible to terminate your NPDES permit.

It appears that construction activities at Home Delivered Congregate Meals are complete. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

Final stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site, and all temporary erosion and sediment control measures have been removed and properly disposed of, and all trapped sediment is permanently stabilized; or

Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Please file the NOT with Ohio EPA's Central Office. The NOT form and instructions can be found on our website at <http://www.epa.ohio.gov/dsw/storm/stormform.html>

If there are any questions, please contact me at (419) 373-3016.

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/lb

Pc: ~~INWDO file~~  
City of Bowling Green