



2GC0139720100326

WOOD HERITAGE DAYCARE 2GC01397 2010/03/26 TEBBE, PATRICIA BOWLING GREE



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
Storm Water
Construction Activity
Permit No. 2GC01397AG

March 26, 2010

Mr. Mark Manley
Debmar Inc
1069 Klotz Rd
Bowling Green, OH 43402

Dear Mr. Manley:

On March 19, 2010, I conducted an inspection of the Heritage Daycare Facility located at 1069 Klotz Road, Bowling Green, Wood County. The purpose of my visit was to evaluate compliance of the site with your National Pollutant Discharge Elimination System (NPDES) Permit for storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of the inspection, construction activities were substantially complete with the building erected and occupied.

The area behind the building has not yet been stabilized and stormwater inlets are not protected. It was also not apparent what post-construction had been installed to control the stormwater drainage from this site.

The Permit requires: portions of the construction site which will be inactive for more than 21 days must have temporary stabilization initiated within the first seven days. Permanent stabilization is required within seven days on any portion of the site that has reached final grade or will be idle for longer than one year. Permanent seeding and mulching is required before construction activity is completed throughout the entire site. If seasonal conditions prohibit the establishment of vegetative cover, other means, such as mulching and matting, must still be used and maintained until more permanent methods can be implemented. *Failure to do so is a violation of Part III.G.2.b.i of your permit.*

Mr. Mark Manley
March 26, 2010
Page 2

The Permit requires: Sediment control structures shall be functional throughout the course of earth disturbing activity. They shall continue to function until the up slope development area is restabilized. *Failure to do so is a violation of Part III.G.2.d.i of your permit.*

Please submit written notification of what corrective measures you have taken to correct the above violations to my attention at this office within 10 days of the date on this letter. If you have any questions, please contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.state.oh.us.

Sincerely,



Patricia A. Tebbe, P.E.
Division of Surface Water

/llr

pc: DSW:NWDO.File . . .
City of Bowling Green
NWDO Follow-up File