



\*2GC0226620090603\*

WOOD

KENTUCKY FRIED CHICKEN

2GC02266 2009/06/03 TEBBE, PATRICIA

ROSSFORD



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korfeski, Director

Re: Wood County  
Kentucky Fried Chicken  
Construction  
Storm Water

June 1, 2009

Mr. Ken Hicks  
Rudolph Libbe Properties  
7255 Crossleigh Court Suite 108  
Toledo Ohio 43617

Dear Mr. Hicks:

On March 19, 2009, I was in the area of the Kentucky Fried Chicken construction site located at 10200 Olde US Rt 20 located in the City of Rossford, Wood County. The observations I made at this time were for the purpose of evaluating compliance of the site with your National Pollutant Discharge Elimination System (NPDES) Permit for storm water associated with construction activity, Construction General Permit (CGP) Facility ID NO. 2GC02266\*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following comments are a result of the inspection:

1. At the time of the inspection, construction had begun and the site was being graded.
2. Silt fence had been erected around the site however it was not entrenched in some areas and in other areas the silt fence was sagging and/or not attached to the stakes.
3. The construction entrance was inadequate to minimize off-site vehicle tracking of sediments and dust which was in evidence.

Within 10 days of the date on this letter, please submit all inspection logs for this site to my attention.

If you have any question I may be contacted at (419) 373-3016 or by e-mail at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us).

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/lb

pc:   
City of Rossford, City Manager