




\*2GR0059520100727\*

---

WOOD	KEYSTONE FOODS LLC EQUIP GRP -	2GR00595	2010/07/27	TEBBE, PATRICIA	NORTH BALTIM
	OHIO DIV				

---



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Wood County  
Keystone Foods – Equity Group  
Industrial Storm Water

July 27, 2010

Mr. Mark Cheney, Engineering Manager  
Keystone Foods  
Equity Group Ohio Division  
2208 Grant Road  
North Baltimore, OH 45872

Dear Mr. Cheney:

On June 28, 2010, a stormwater compliance inspection was made of the Keystone Foods Equity Group – Ohio Division, North Baltimore, Wood County to determine compliance with the National Pollutant Discharge Elimination System General Permit for Storm Water Associated with Industrial Activity (IGP) issued to this facility. The inspection consisted of a tour of the grounds outside of this facility and a review of the Stormwater Pollution Prevention Plan (SWP3).

The outside inspection found no storage of waste or raw materials outside of the building. The first five minutes of a storm event goes to the pretreatment wastewater plant which discharges to the North Baltimore wastewater treatment plant with the remaining flow to the onsite stormwater detention pond.

A review of the SWP3 shows that the plan is not up to date and the required inspections are not being completed as required by the IGP. Please advise when you have updated the SWP3.

The IGP is set to expire on May 31, 2011. You may wish to check our website at <http://www.epa.ohio.gov/dsw/storm/index.aspx> periodically for any updates on the IGP renewal. Once the IGP is drafted and ready for public comment it will be available for viewing on our website.

If you have any questions, please contact me at (419) 373-3016 or by e-mail at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us).

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/lb

pc:  DSW\NWDO.file