



\*2GC0242020100708\*

---

WOOD	MID-WOOD INC COOPERATIVE SERVICE CTR	:2GC02420 2010/07/08	TEBBE, PATRICIA	CYGNET
------	---	----------------------	-----------------	--------



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Re: Wood County  
Mid-Wood Coop Service Ctr  
Construction Storm Water

July 8, 2010

Mr. Tom Dorman  
Mid-Wood Inc.  
PO Box 799  
Bowling Green, OH 43402

Dear Mr. Dorman:

On June 4, 2010, I conducted an inspection of the Mid-Wood Inc. Cooperative Service Center which is being constructed at 12965 Defiance Pike, Wood County. The purpose of my visit was to evaluate compliance of the site with your National Pollutant Discharge Elimination System (NPDES) Permit for storm water associated with construction activity (construction general permit or CGP), Facility ID no. 2GC02420\*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. There are no co-permittees listed for this permit.

As a result of the inspection, I have the following comments:

1. At the time of the inspection the main buildings had been erected but were not finished.
2. A berm on the west side of the site was being worked. Please remember that the CGP requires that temporary stabilization is required on any undisturbed areas that will be dormant for more than 21 days.
3. Silt fence had been erected around most of the perimeter of the site but had not been entrenched or maintained. *The Permit requires: Sediment control structures shall be functional throughout the course of earth disturbing activity. They shall continue to function until the up slope development area is restabilized. Failure to do so is a violation of Part III.G.2.d.i of your permit*
4. A catch basin on the south side had no inlet protection. While there is a sedimentation pond present it appears that farm runoff and sediment from the site will enter this catch basin.
5. Much of the site is stoned and there is a good construction entrance with no tracking onto Defiance Pike.

I understand that floor drains are being proposed in the buildings. Any discharges from these drains are to be discharged to the sanitary sewer.

Mr. Tom Dorman  
July 8, 2010  
Page Two

Any discharge from inside the building into the storm pond would require a National Pollutant Discharge Elimination Permit however, the Anti-degradation rule (Ohio Administrative Code 3745-1-05) requires that the best available demonstrated control technology be used for any discharge. In this case that would be the sanitary sewer. Please contact the Northwestern Water and Sewer District for any requirements they may have for this discharge into their sewer.

If you have any questions, you may contact me at (419) 373-3016 or by e-mail at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us).

Sincerely,



Patricia A. Tebbe, P.E.  
Division of Surface Water

/lb

pc: [REDACTED]  
Mike Dunipace  
Wood County SWCD  
Wood County Engineer