



2GC0101420090603

WOOD PENTA CAREER CTR 2GC01014 2009/06/03 TEBBE, PATRICIA PERRYSBURG



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
Penta Career Center
Construction Storm Water

June 3, 2009

Mr. Phillip G. Enderle
The Collaborative Inc.
500 Madison Avenue
Toledo, Ohio 43604

Dear Mr. Enderle:

On September 17, 2008, a Notice of Termination (NOT) was issued for the Penta Career Center construction site. The terms of the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity or Construction General Permit (CGP) state that an NOT may be filed once final stabilization has been achieved on ALL portions of the site for which the permittee is responsible or if another operator has assumed control over all areas of the site that have not been finally stabilized.

On May 28, 2009, I conducted an inspection of the Penta Career Center site located at 9301 Buck Rd., Perrysburg Township, Wood County. The purpose of my visit was to evaluate compliance of the site with your National Pollutant Discharge Elimination System (NPDES) Permit for storm water associated with construction activity, Facility ID no. 2GC01014*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

During this inspection I observed numerous areas that did not have 70% final stabilization mainly on open grass areas, berms, and along roadways. Since no other NOI has been submitted for operator coverage for this site, the NOT submitted for this site may be invalid.

I also observed a new construction site near the plant operations area and an area near the emergency entrance along Lime City Road that was being used for stockpiling of soil. Neither area appeared to have sediment or erosion controls including construction entrances. Sediment tracking was observed on the roadway.

Mr. Phillip G. Enderle
June 3, 2009
Page 2

Within 10 days of the date of this letter, please submit to this office, the part of your Storm water Pollution Prevention Plan which is to include all of the data and specifications for the post-construction controls for this site, and written notification of what corrective measures will be taken on the above noted deficiencies.

If there are any questions, please feel free to contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.state.oh.us.

Sincerely,



Patricia A. Tebbe, P.E.
Division of Surface Water

/llr

pc: ~~DSW/NWDO File~~
Wood County Engineer
NWDO Follow-up File