2GC0236520100810

WYANDOT	TRAILER WASH	2GC02365	2010/08/10	CLEMENT, SARAH	UPPER SANDUS

Ohio | Environmental Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Wyandot County
Trailer Wash
Construction
Storm Water

August 10, 2010

Mr. Todd Stickley
PSD Development LLC
7148 State Route 199
Upper Sandusky, Ohio 43351

Dear Mr. Stickley:

On July 27, 2010, Sarah Clement and Judson Delancey inspected Kalmbach Trailer Wash Facility at 7148 State Route 199 in Crawford Township. The purpose of the inspection was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No 2 GC02365*AG. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111. Ohio EPA has no record of other permittees for this site. As a result of the inspection, your site may be eligible for termination of your NPDES permit.

It appears that construction activities at Kalmbach Trailer Wash Facility are complete. The work on the building was finished and gravel had been laid on the drive. Accordingly, a Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been achieved on all portions of the site for which the permittee is responsible. Final stabilization means that either:

    1. All soil disturbing activities are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment controls have been removed, properly disposed of, and all trapped sediment has be permanently stabilized.

    2. For construction projects on land used for agricultural purposes, final stabilization may be achieved by returning the disturbed land to its pre-construction agricultural use. If not returned to its pre-construction agricultural use, the land must meet the final stabilization criteria in (1) above.

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Your site does not meet the above criteria at this time. The disturbed land to the north, west, and south of the building had no vegetative growth. This area should be reseeded in order to achieve a 70% vegetative density.

When a uniform growth density of at least 70% has been established across the entire site and the post construction storm water management facility has been installed, the site will be eligible to file the NOT form. The form can be found on our website: http://www.epa.ohio.gov/dsw/storm/stormform.aspx. NOTs must be filed with Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,

Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/llr

pc: DSW-NWDO File
Michael Kohl, Wyandot County Engineer
Wyandot County SWCD