




**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

September 18, 2012

Mr. Tim Smith
Brentwood Community MHP LLC
103 A Degroff Avenue
P.O. Box 218
Archbold, Ohio 43502

Paulding County
Brentwood Community MHP LLC
Community PWS

PWS ID: OH6300212

Dear Mr. Smith:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) submitted by Brentwood Community MHP Inc. reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system August 16, 18, and 19.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at (419) 373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/cg

pc: Thomas Roth, Operator
Paulding County Health Department
NWDO – DDAGW

